



Development Services
638 Princess Ave, Brandon MB R7A 0P3
Ph: 204-729-2110 Fx: 204-728-2406

CERTIFICATION OF HYDRONIC HEATING SYSTEM

Site Address	
Building Permit No.	

The design and installation of the heating system at the above noted address is in compliance with Section 9.33 of the Manitoba Building Code.

Specifically:

- The system conforms to CAN/CSA-B214, "*Installation Code for Hydronic Heating Systems*."
- All control equipment, component parts and systems are installed to provide easy access for inspection, maintenance and cleaning.
- All systems and respective thermostats are operational and functioning in good working order.
- The system is capable of maintaining an indoor air temperature of 22 degrees Celsius at the outside winter design temperature as described in Article 9.33.3.1.

Certified this _____ day of _____, 20____

Heating Contractor

Company

Principal

Address

Phone Number

Signature

General Contractor/Owner

Company

Owner

Address

Phone Number

Signature