



Planning & Building Safety Department
 638 Princess Ave, Brandon, MB R7A 0P3
 Ph: 204-729-2110 Fx: 204-728-2406

CERTIFICATION OF EARTH ENERGY HEATING SYSTEM

Site Address	
Building Permit No.	

The design and installation of the heating system at the above noted address is in compliance with Section 9.33 of the Manitoba Building Code.

Specifically:

- The system conforms to CAN/CSA-C448 SERIES, *“Design and Installation of Earth Energy Systems.”*
- All control equipment, component parts and systems are installed to provide easy access for inspection, maintenance and cleaning.
- All systems and respective thermostats are operational and functioning in good working order.
- The system is capable of maintaining an indoor air temperature of 22 degrees Celsius at the outside winter design temperature as described in Article 9.33.3.1.

Certified this _____ day of _____, 20_____

Heating Contractor

General Contractor/Owner

 Company

 Company

 Principal

 Owner

 Address

 Address

 Phone Number

 Phone Number

 Signature

 Signature