

Brandon Fire and Emergency Services



Canned Liquid Fuel Heaters Regulation – “P4”

The following Regulation is in accordance with the City of Brandon’s Fire Prevention By-Law #7200

Canned liquid fuel heaters may be used for food warming purposes provided

- ❑ The fuel is in commercially manufactured, prepackaged cans,
- ❑ Is used with a chafing dish equipped with a fuel can holder,
- ❑ It is kept away from combustible materials such as napkins, papers and decorations,
- ❑ Warming devices shall not exceed 288 sq. inches (17” x 17” approx.) of surface area,
- ❑ A maximum of (2) cooking and/or warming devices shall be permitted per booth. At least 2 feet of distance shall be maintained between cooking devices at all times,
- ❑ Re-warming devices shall be placed on a non-combustible surface,
- ❑ Re-warming devices shall be kept a minimum of 2 feet from combustible materials,
- ❑ Re-warming devices and heated products must be isolated away from the public or be protected with a clear plastic shield,
- ❑ A minimum 5 lbs. ABC dry chemical fire extinguisher, with a current inspection tag, shall be provided for each booth containing heat producing appliances.

Care must be taken not to spill the fuel.

Fuel containers must be closed and disposed of properly after use.